




AUTOMATIC FLUSHING ASSEMBLY (TYPE B) 44W




RIP-RAP RUBBLE DETAIL 45W




LANDSCAPE AND ROOT BARRIER DETAIL * 46W



ABOVE GROUND WATER METER INSTALLATION PIPE SUPPORT 47W



POTABLE WATER MAIN CROSSING FENCE, WALL, OR BERM CASING DETAIL* 48W



POTABLE WATER MAIN CONFLICT STRUCTURE DETAIL* 49W

WUD MAIN SIZE	DIAMETER OF STEEL CASING	OPENING SIZE FOR SOLID CASING	OPENING SIZE FOR SPLIT CASING
6"	14"	18"	20"
8"	20"	24"	28"
10"	26"	30"	34"
12"	32"	36"	40"

THIS SPACE INTENTIONALLY LEFT BLANK

POTABLE WATER #6 STANDARD DETAILS

CONSULTANT: IT'S THE LAW!
CALL 48 HOURS BEFORE YOU DIG
1-800-432-4770
SUNSHINE STATE ONE CALL OF FLORIDA, INC.
UTILITIES NOTIFICATION CENTER

DESIGNED BY: WUD
DRAWN BY: M. BUCKNER
CHECKED BY: J. LAMMERT
APPROVED BY: WUD

Palm Beach County
Water Utilities Department
P.O. Box 16097
West Palm Beach, FL 33416-6097

SHEET NUMBER 0 OF 0

Mar 01, 2023